



Permit and License Flowchart – Flammable Storage/Use



PROPERTY OWNER FLAMMABLE STORAGE / USE	
List Each Floor	Class 1:
	Class 2:
	Class 3:
	Flammable Solids/Gases:
List total amounts per floor. Please indicate if storage is for generators, laboratory use, vehicles in garage, etc.	

TENANT FLAMMABLE STORAGE / USE	
List Each Floor	Class 1:
	Class 2:
	Class 3:
	Flammable Solids/Gases:
List total amounts per floor. Please indicate if storage is for generators, laboratory use, vehicles in garage, etc.	

Is storage compliant with 780CMR SECTIONS 307 & 417?
(MASS STATE BUILDING CODE – HAZARDOUS MATERIALS)
(affidavit required)

Reduce quantity of flammables or meet 780CMR storage requirements

NO

YES

Additional information, forms and permit applications can be found by visiting:
www.cambridgema.gov
www.mass.gov/dfs/osfm

Has a Fire Department FLAMMABLE STORAGE PERMIT been applied for? (527CMR§14)

Apply for Fire Department **FLAMMABLE STORAGE PERMIT**
CFD ANNUAL PERMIT (527CMR§14)

NO

YES

FLAMMABLE STORAGE IN UNDERGROUND OR ABOVEGROUND TANKS MUST FOLLOW 527CMR§9 REGULATIONS
CFD FP 6 TANK INSTALL PERMIT
STATE FIRE MARSHAL UST REGISTRATION FORMS
SFMO FP 290 PART 1 & 2 – UST/AST REGISTRATION
SFMO FP 290 PART 3 – UST/AST PERMIT APPLICATION
SFMO FP 290R – UST/AST REMOVAL NOTIFICATION
SFMO FP 292 – UST/AST REMOVAL APPLICATION

OIL BURNER INSTALLATIONS FOLLOW 527CMR§4 REGULATIONS
SFMO FORM 1
+10 GALLONS – FORM 1
+10,000 GALLONS – LICENSE

Add total quantities of flammables stored and used (COMBINE PROPERTY OWNER AND TENANTS FIRE PERMITS)

Is License Required?

NO

YES

PROPERTY OWNER MUST APPLY FOR LICENSE (MGL148§13)
(Apply to Cambridge License Commission)
SFMO FP5 – CERTIFICATE OF REGISTRATION
CLC Licensed Premises Inspection Approvals Form

LICENSE REQUIRED IF AMOUNTS EXCEED:
CLASS 1 – 793 gallons
CLASS 2 – 10,000 gallons
CLASS 3A – 10,000 gallons
CLASS 3B – 10,000 gallons
FLAMMABLE GASES (inside) – 3000 CU.FT.
FLAMMABLE GASES (outside) – 10,000 CU.FT.
FLAMMABLE SOLIDS – 100 LBS
(FD PERMIT ONLY IF LESS THEN THESE AMOUNTS)

NOTE: A FIRE DEPT PERMIT IS REQUIRED IN ADDITION TO THE LICENSE (527CMR§14:03)