



SECTION A-A
SEWER OR DRAIN SERVICE CONNECTION < 12' DEEP

- NOTES:
1. REPLACE EXISTING SERVICE LATERAL TO EXTENT REQUIRED.
 2. EXCAVATE AND REMOVE EXISTING LATERAL AS REQUIRED TO ALLOW RECONSTRUCTION.
 3. FOR SEWER AND DRAIN SERVICE CONNECTIONS TO MAINLINE 18" IN DIAMETER OR GREATER AN INSERTA TEE OR EQUAL MAY BE USED.
 4. FOR SERVICE CONNECTIONS > 12' DEEP FROM INVERT OF MAINLINE PIPE TO FINISHED GRADE, SEE CHIMNEY DETAIL.
 5. SEWER AND DRAIN LATERALS SHALL BE SIZED TO FIT ANTICIPATED FLOWS BUT SHALL NOT BE LESS THAN 6" FOR SEWER SERVICES AND 8" FOR DRAIN SERVICES

SEWER OR DRAIN SERVICE LATERAL RECONNECTION FOR CONFLICTS WITH OTHER UTILITIES



SEWER OR DRAIN SERVICE CONNECTION

CITY OF CAMBRIDGE STANDARD SPECIFICATIONS AND DETAILS

| | | | |
|---------------|----------------------|---------------------------|--------|
| SCALE: N.T.S. | DATE OF ISSUE: 02/05 | SPEC. SECTION REF#: 02622 | 2622.1 |
|---------------|----------------------|---------------------------|--------|