

Updated: 10/26/21

**Cambridge Water Department Per- and Polyfluoroalkyl Substances (PFAS) Monitoring - Analytes detected  
Entry Point to the Distribution System (EPDS) aka Finish Water**

Compound Name	1/6/2021	2/3/2021	3/29/2021	4/1/2021	5/3/2021	6/2/2021	7/7/2021	8/4/2021	9/1/2021	10/4/2021		
	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)	ng/L (ppt)		
<b>Perfluorooctane Sulfonic Acid (PFOS)</b>	1.7	1.7	1.9	2.2	2.4	3.0	4.3	4.3	4.7	3.5		
<b>Perfluorooctanoic Acid (PFOA)</b>	6.9	6	8.5	7.9	6.8	7.8	7.9	8.3	9.6	8.5		
<b>Perfluorohexane Sulfonic Acid (PFHxS)</b>	2.1	2.3	3.03	3.57	2.5	3	2.8	2.9	3	2.9		
<b>Perfluorononanoic Acid (PFNA)</b>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0		
<b>Perfluorohepatanoic Acid (PFHpA)</b>	3.2	3	2.4	3.4	2.3	2.9	2.9	3	3.4	2.9		
<b>Perfluorodecanoic acid (PFDA)</b>	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0		
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov.	Dec.
Sum of PFAS6	12.2	11.3	15.8	17.1	14.0	16.7	17.9	18.5	20.7	17.8	-	-
Quarterly Compliance Average	<b>13.1</b>			<b>15.9</b>			<b>19.0</b>					
Compliance with Regulation?	<b>YES</b>			<b>Yes</b>			<b>Yes</b>					