



**Elizabeth Unger**  
Purchasing Agent

# City of Cambridge

PURCHASING DEPARTMENT

**SHUO WANG**  
Assistant Purchasing Agent for  
Goods & Services

**NATALIE SULLIVAN**  
Assistant Purchasing Agent for  
Design & Construction

**TO:** All Bidders

**FROM:** City of Cambridge

**DATE:** November 13, 2023

**RE:** File No. 11239 – Rindge Commons Pre-K Interior Fit-Out - Addendum No. 3

---

This addendum is comprised of the following:

1. Questions and Answers (Attached)
2. Updates to Specifications (Attached)

All other details remain the same.

**Elizabeth Unger**  
Purchasing Agent

**Addendum No. 3**



# Rindge Commons Pre-K Interior Fit-Out

Cambridge, Massachusetts

## ADDENDUM #3

November 13, 2023

---

### BIDDER QUESTIONS

---

- **ITEM 2.1**      Question: Spec 096500-2.01-E-1.b shows the rubber tile flooring size as 24"x48" but the Basis of Design products do not come in that size. Should we be carrying 12"x24" or 24"x24"?  
  
Response: Please carry 24" x 24" rubber tile.
- **ITEM 2.2**      Question: What flooring should be carried at Closet 201A? Finish Plan A8.2 shows VQT but Finish Schedule A8.2 shows Rubber.  
  
Response: Please use VQT flooring in Closet 201A.
- **ITEM 2.3**      Question: What flooring should be carried at Closet 219A? Finish Plan A8.2 shows CPT but Finish Schedule A8.2 shows Rubber.  
  
Response: Please use carpet tile flooring in Closet 219A.
- **ITEM 2.4**      Question: What wall base should be carried at all Toilet Rooms? Elevations on A7.1 show Epoxy Cove Base but Finish Schedule A8.2 shows Coved CT.  
  
Response: Please see similar question in Addendum 2.
- **ITEM 2.5**      Question: If Toilet Rooms are to receive Epoxy Cove Base, please confirm which trade should carry the metal strip between top of cove and bottom of wall tile. What finish should the metal strip be... aluminum or stainless steel?  
  
Response: Please see similar question in Addendum 2.
- **ITEM 2.6**      Question: What wall finish should be carried at Custodian 215? Elevations on A6.3 show P-LAM but Finish Schedule A8.2 shows CT.  
  
Response: Please see updated finish schedule in Addendum 2.

# Rindge Commons Pre-K Interior Fit-Out

Cambridge, Massachusetts

## PROJECT MANUAL

---

### PART B - SPECIFICATIONS

- **ITEM 2.7** SECTION 00001 – TABLE OF CONTENTES: DELETE reference to 012200a Unit Price Proposal sheet. There are no unit prices on this project.

## ATTACHMENTS

None

End of Addendum No. 3