



Permit and License Flowchart – Flammable Storage/Use



PROPERTY OWNER FLAMMABLE STORAGE / USE	
List	Class 1:
Each	Class 2:
Floor	Class 3:
	Flammable Solids/Gases:

List total amounts per floor. Please indicate if storage is for generators, laboratory use, vehicles in garage, etc.

TENANT FLAMMABLE STORAGE / USE	
List	Class 1:
Each	Class 2:
Floor	Class 3:
	Flammable Solids/Gases:

List total amounts per floor. Please indicate if storage is for generators, laboratory use, vehicles in garage, etc.

Is storage compliant with 780CMR SECTIONS 307 & 417?
(MASS STATE BUILDING CODE – HAZARDOUS MATERIALS)
(affidavit required)

NO

YES

Has a Fire Department FLAMMABLE STORAGE PERMIT
been applied for? (527CMR§14)

NO

YES

Apply for Fire Department
FLAMMABLE STORAGE PERMIT
CFD ANNUAL PERMIT (527CMR§14)

FLAMMABLE STORAGE IN UNDERGROUND
OR ABOVEGROUND TANKS MUST FOLLOW
527CMR§9 REGULATIONS

CFD FP 6 TANK INSTALL PERMIT
STATE FIRE MARSHAL UST REGISTRATION FORMS
SFMO FP 290 PART 1 & 2 – UST/AST REGISTRATION
SFMO FP 290 PART 3 – UST/AST PERMIT APPLICATION
SFMO FP 290R – UST/AST REMOVAL NOTIFICATION
SFMO FP 292 – UST/AST REMOVAL APPLICATION

OIL BURNER INSTALLATIONS
FOLLOW 527CMR§4 REGULATIONS

SFMO FORM 1
+10 GALLONS – FORM 1
+10,000 GALLONS – LICENSE

Add total quantities of flammables stored and used
(COMBINE PROPERTY OWNER AND TENANTS FIRE PERMITS)

Is License Required?

NO

YES

PROPERTY OWNER MUST APPLY FOR LICENSE (MGL148§13)
(Apply to Cambridge License Commission)
SFMO FP5 – CERTIFICATE OF REGISTRATION
CLC Licensed Premises Inspection Approvals Form

Additional information, forms and
permit applications can be found
by visiting:
www.cambridgema.gov
www.mass.gov/dfs/osfm

LICENSE REQUIRED IF AMOUNTS EXCEED:

CLASS 1 – 793 gallons
CLASS 2 – 10,000 gallons
CLASS 3A – 10,000 gallons
CLASS 3B – 10,000 gallons

FLAMMABLE GASES (inside) – 3000 CU.FT.
FLAMMABLE GASES (outside) – 10,000 CU.FT.
FLAMMABLE SOLIDS – 100 LBS

(FD PERMIT ONLY IF LESS THEN THESE AMOUNTS)

**NOTE: A FIRE DEPT PERMIT IS REQUIRED IN
ADDITION TO THE LICENSE (527CMR§14.03)**