Cambridge tap water:
Current information about PFAS testing (Feburary 2022)
Test Results

PFAS Analyte PFAS6 (regulated)	Result ng/L (ppt)
Perfluorooctane Sulfonic Acid (PFOS)	2.0
Perfluorooctanoic Acid (PFOA)	5.7
Perfluorohexane Sulfonic Acid (PFHxS)	2.1
Perfluorononanoic Acid (PFNA)	Not Detected
Perfluorohepatanoic Acid (PFHpA)	1.9
Perfluorodecanoic acid (PFDA)	Not Detected
Sum of PFAS6 - compare to MassDEP MCL of 20 ng/L	**11.7**

*Trace amounts are present, but below the minimum concentration that can be reported as a quantified value.
MCL = Maximum Contaminant Level
ng/L = nanogram per liter
ppt = parts per trillion

PFAS = Per and Poly Fluoroalkyl Substances