

**Cambridge Fire Department**  
**Inspection Form for**  
**Unvented Gas Heater Systems**  
**527 CMR 6.00 - 527 CMR 30.00**  
**248 CMR – MGL c.148 s.25A - MGL c.148 s.26E**  
**ANSI Z21.11.2**

CFD Project # \_\_\_\_\_ Permit Date: \_\_\_\_\_ Inspection Date: \_\_\_\_\_

CFD Inspector: \_\_\_\_\_ Permit Recipient: \_\_\_\_\_

Project Name: \_\_\_\_\_ Project Address: \_\_\_\_\_

Installation Plumber: \_\_\_\_\_ Installer License: \_\_\_\_\_

Installation Company: \_\_\_\_\_ Installer Ph: \_\_\_\_\_

Location of installation (no bedroom/bathroom): \_\_\_\_\_

Approved system make and model: \_\_\_\_\_

BTU's ( $\leq 40,000$ ) \_\_\_\_\_

**SYSTEM REQUIREMENTS**

Yes	No	N/A	
___	___	___	Copy of installation/operating instructions
___	___	___	System approved by Plumbers and Gasfitters Board
___	___	___	System equipped with oxygen depletion safety shutoff (ODS)
___	___	___	Carbon monoxide detector in area of installation
___	___	___	Smoke detectors preinstalled for building
___	___	___	Is primary heat source permanently installed Type _____
___	___	___	Copy of 527 CMR 30.00 from seller
___	___	___	Appliance permanently affixed or mounted
___	___	___	Natural gas installation, if yes requires permanent piping
___	___	___	LPG appliances, if yes subject to storage requirements of 527 CMR 6.00
___	___	___	Clearance to combustibles    Number of feet _____

***Note: Vent-free gas products include gas fireplaces and fireplace inserts, gas logs, gas stoves and room heaters. The sale or use of portable unvented gas fired heaters inside buildings used for human habitation is prohibited.***

\_\_\_ System Approved

\_\_\_ System Disapproved

Date: \_\_\_\_\_

Inspector's Initials \_\_\_\_\_