CERTIFICATE OF ANALYSIS

CAMBRIDGE DEPARTMENT OF PUBLIC WORKS

147 HAMPSHIRE ST. CAMBRIDGE, MA 02139

RE: CHARLES RIVER EPA-DEP STORM DRAIN SAMPLES

Sample Collection: Samples collected by Client

Received Date/Time: 11/7/06, 2:00 PM

Analytical Results:

SAMPLE ID	1	2
DATE COLLECTED	11/7/06	11/7/06
LOCATION	First at Thorndike	Endicott Street
pH Value (S.U.)	6.97	7.22
Conductivity (µmhos/cm)	585	695
Fecal Coliform / 100mL	800	> 80,000
E.Coli / 100mL	800	> 80,000
Enterococci / 100mL	300	> 80,000
Ammonia Nitrogen (mg/L)	0.46	26.8
Total Kjeldhal Nitrogen (mg/L)	0.65	30
Nitrate Nitrogen (mg/L)	2.38	13.04
Total Phosphorus (mg/L)	0.064	3.0
Biochemical Oxygen Demand (mg/L)	< 2	30
Total Suspended Solids (mg/L)	10	. 60

Report No.: 39064
Report Date: 11/20/06

Page 1 of 1

G & L Laboratories, Inc.

Diana Liu Lab Director