

Contaminant	Highest Level Detected	Range	MCL	MCLG	Violation	How it gets in the water
Total Coliform	1 positive in two months	1 positive July 1 positive December	Greater than 5% in one month	zero	NO	Naturally present in the environment
Turbidity	0.27	0.043 to 0.27	TT = 0.3 NTU	n/a	NO	Soil Runoff
	100% lower than MCL		TT=95% of samples <0.3		NO	
Disinfectant	Highest Level Det.		MRDL	MRDLG		
Chloramines (as Cl ₂)	3.78	0.23 to 3.78	4 mg/l	4	NO	Water additive used to control microbes
Disinfection By-products	Highest RAA		MCL	MCLG		
Bromate	2	0 to 2.0	10 ppb	0	NO	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	8.9	0.76 to 8.9	80 ppb	n/a	NO	Byproduct of drinking water disinfection
Total Haloacetic Acids (THAA)	4.7	4.5 to 4.7	60 ppb	n/a	NO	Byproduct of drinking water disinfection
Inorganic Chemicals	Highest Level Det.	Range	MCL	MCLG		
Arsenic	0.3	0.3	10 ppb	0	NO	Erosion of natural deposits
Barium	0.035	0.035	2 mg/l	2	NO	Erosion of natural deposits
Chromium	2		100 ppb	100	NO	Erosion of natural deposits
Fluoride	1.27	0.91 to 1.27	4 mg/l	4	NO	Additive which promotes strong teeth
Nickel	1.000		100 ppb	n/a	NO	Erosion of natural deposits
Nitrate as Nitrogen	0.52	0.35 to 0.52	10 mg/l	10	NO	Runoff from fertilizer use.
Nitrite as Nitrogen	0.12	0 to 0.12	1 mg/l	1	NO	Runoff from fertilizer use.
Selenium	0.5		50 ppb	50	NO	Erosion of natural deposits
Sodium	76		n/a (mg/l)	n/a	NO	Road Salt
Unregulated Organic Chemicals	Highest Level Det.	Range	Units			
Bromoform	1	0.8 to 1.0	ppb	-	NO	Byproduct of drinking water disinfection
Bromodichloromethane	4	1.0 to 4.0	ppb	-	NO	Byproduct of drinking water disinfection
Chlorodibromomethane	5	1.0 to 5.0	ppb	-	NO	Byproduct of drinking water disinfection
Chloroform	4	0.6 to 4.0	ppb	-	NO	Byproduct of drinking water disinfection
Lead and Copper-2011 100 sites	90% Value	Range	AL= 90% value	MCLG		
Lead	5	0 - 31 (2 sites over the Action Level)	15 ppb	0	NO	Corrosion of household plumbing
Copper	0.039	0.002 - 0.053	1.3 mg/l	0	NO	Corrosion of household plumbing